

# CAEP

## *Submittal Documents*

### *Seismic Analysis of the Boiler SVF 1100*



*August 08, 2018*

*For:*  
***WEIL-McLAIN***

Prepared By:  
Sam Salissen, ME, PE, Ph.D.

## *Summary*

The scope of this report is the seismic qualification, based on the structural analysis, of the boiler model SVF 1100, under the seismic loads for the seismic zone 4 in the United States. The analyses are limited to the load path from the COG of the assembly to the floor and the interior parts of the boiler are not within the scope of this work.

The qualification is in accordance with the seismic design requirements of IBC 2015, ASCE 7-10 and AISC for the seismic zone 4, for non-structural components and based on the seismic parameters used in this report.

The structural analyses carried out on the base frame assembly and based on the safety factors reported in section **5.7**, the minimum safety factor of **1.67**, requirement of AISC, is obtained in all the analyses performed in this report.

It is concluded that the design of the main frame and legs meets the design requirements of IBC 2015, ASCE 7-10 and ASME BPVC and AISC standards. This conclusion is contingency to the accuracy of the SolidWorks model and other input data provided by WEIL-McLAIN (WM) and used to build the FE models and set up the analyses (material, COG,...) appended in Appendix 1.

***Revision History***

| Rev | Date       | Scope of the revision | Created by   |
|-----|------------|-----------------------|--------------|
| A   | 08/06/2018 | First Issue           | Sam Salissen |

# Table of Contents

|       |  |    |
|-------|--|----|
| 1     | Introduction .....                             | 6  |
| 1.1   | Scope .....                                    | 6  |
| 2     | Assumptions and open issues .....              | 6  |
| 3     | Requirements and Prerequisites.....            | 7  |
| 3.1   | Stress criteria .....                          | 7  |
| 3.2   | Loads .....                                    | 7  |
| 4     | Analyses' model .....                          | 9  |
| 4.1   | The extent of the model.....                   | 9  |
| 4.2   | Material data.....                             | 9  |
| 5     | Stress Analyses.....                           | 10 |
| 5.1   | Analysis of assembly: Load Case 1.....         | 10 |
| 5.2   | Analysis of assembly: Load Case 2.....         | 11 |
| 5.3   | Analysis of assembly: Load Case 3.....         | 13 |
| 5.4   | Analysis of assembly: Load Case 4.....         | 14 |
| 5.5   | Analysis of Welds .....                        | 16 |
| 5.5.1 | Welds between base frame and top plate .....   | 16 |
| 5.6   | Analysis of Bolts .....                        | 17 |
| 5.6.1 | Bolts between stands and base frame.....       | 17 |
| 5.6.2 | Bolts between cover plate and base frame ..... | 18 |
| 5.6.3 | Anchor Bolts .....                             | 19 |
| 5.7   | Results Evaluation.....                        | 20 |
| 6     | Conclusion.....                                | 20 |
| 7     | References .....                               | 21 |

## **APPENDICES**

*APPENDIX 1- Drawing with COG markup*

*APPENDIX 2- Anchor Bolt Calculation Report*

# ***1 Introduction***

## ***1.1 Scope***

The scope of this report is the seismic qualification, based on the structural analysis, of the boiler, model SVF 1100, under the seismic loads for the seismic zone 4 in the states. The analyses are limited to the load path from the COG of the assembly to the floor and the interior parts of the boiler are not within the scope of this work. The qualification is in accordance with the design requirements of IBC 2015, ASCE 7-10 and AISC.

## ***2 Assumptions and open issues***

In this chapter, assumptions and open issues are presented in two categories. The definition of each is presented below.

***Open issues-*** Is defined as issues that must be solved, otherwise the analysis cannot be completed.

***Key assumption-*** Is defined as assumptions that may have noticeable impact on the analysis results.

### **2.1 Open Issues**

- No open issues exist.

### **2.2 Key Assumptions**

No fabrication drawing of the parts and assembly were provided and the analyses are based on the SolidWorks model that is provided by WM and no responsibility of the accuracy of the model with respect to the actual assembly will be taken by the author of this report.

- The weight and the location of the center of the gravity of the boiler assembly are estimated and provided by WM, Appendix 1.
- It is assumed that the material of the base frame and the top plate are S235JR and SS316L, respectively.
- It is assumed that the welds have at least the same strength as the base material (Weld strength  $F_{EXX} = 70 \text{ksi} > 54 \text{ksi}$  for base material) based on ASME allowable stress in welds under shear and tension is  $0.3 \cdot \text{tensile strength} = 21000 \text{psi}$ . In this case it is lower than the allowable stress of the in the members (AISC).

### 3 Requirements and Prerequisites


#### 3.1 Stress criteria

The seismic loads are calculated based on the IBC 2015 code. The detail of the used parameters and the calculations are as follows. Seismic analyses are performed (using FEM) based on ASD approach of the AISC 14 edition & ASCE 7-10 for the steel parts and LRFD for the anchorage calculations.


#### 3.2 Loads

The four load cases consider during the analyses include those specified by the ASCE 7-10. The following parameters are used in calculation of the seismic loads as follows:

- 1- Load calculation for ASD (used in the analyses of the steel parts)

|   |                          |   |  |  |   |                        |
|---|--------------------------|---|--|--|---|------------------------|
| <br>14271 Jeffery Rd.,<br>Irvine, CA 90032<br>PH (949) 923 9073 FX (949) 264 7184<br><a href="http://www.caepiping.com">www.caepiping.com</a><br>"CALL US - TO SET THINGS RIGHT" | JOB NAME:<br>SA-SVF1100  | SEISMIC CALCULATION WORKSHEET<br>BUILDING CODE<br>IBC-2012 / 2015   | SEISMIC DESIGN    BLDG. ELEVATION<br>S <sub>ds</sub> = 2                    / EQUIP. LOCATION<br>I <sub>p</sub> = 1                    h = 40 ft<br>a <sub>p</sub> = 1                    **z = 40 ft<br>R <sub>p</sub> = 2.5                ** Assume worst<br>Ω <sub>0</sub> = 2.0                case location.<br>a <sub>p</sub> , R <sub>p</sub> , Ω <sub>0</sub> per ASCE 7-10 | X 40 ft. RF<br>0 ft. GF<br>or below ground | LOAD COMBINATION<br>ASD 2012/ 2013<br>( 0.6 DL + 1.75 E ) |                        |
|   | CUSTOMER:<br>WEIL-McLAIN | DATE:    PRP. BY.:    CAE PIPING JOB #:<br>8/3/2018   |  |  |   |                        |
| EQUIPMENT TAG: BOILER SVF 1100  |                          | APPLIED SEISMIC FORCE/ CALCULATIONS:  |  |  | ANCHORAGE TO CONCRETE                                     | SHT. NUMBER:<br>1 OF 1 |
| EQUIPMENT Information:<br>W <sub>p</sub> = max. operating weight = 2695 lbs.  |                          | $F_p / W_p = ( 0.4 \times a_p \times S_{ds} \times ( 1 + ( 2 \times ( z / h ) ) ) / ( R_p / I_p ) ) = 0.96$ $F_p / W_p = 0.96g ; F_{p,min} / W_p = 0.3 \times S_{ds} \times I_p = 0.60 ; F_{p,max} / W_p = 1.6 \times S_{ds} \times I_p = 3.20$ $F_{ph} = \text{Applied Lateral Seismic Force} = 1.8 \times 0.96g \times W_p = 4528 \text{ lbs. } \text{"WORST CASE"}$ $F_{pv} = \text{Vertical component of seismic force} = 1.0 \times 0.2 \times S_{ds} \times W_p = 1078 \text{ lbs. } \text{"WORST CASE"}$ |  |  |   |                        |

- 2- Load calculation for LRFD (used in the analyses of the anchorage)

|   |                          |   |  |  |  |                        |
|---|--------------------------|---|--|--|--|------------------------|
| <br>14271 Jeffery Rd.,<br>Irvine, CA 90032<br>PH (949) 923 9073 FX (949) 264 7184<br><a href="http://www.caepiping.com">www.caepiping.com</a><br>"CALL US - TO SET THINGS RIGHT" | JOB NAME:<br>SA-SVF1100  | SEISMIC CALCULATION WORKSHEET<br>BUILDING CODE<br>IBC-2012 / 2015   | SEISMIC DESIGN    BLDG. ELEVATION<br>S <sub>ds</sub> = 2                    / EQUIP. LOCATION<br>I <sub>p</sub> = 1                    h = 40 ft<br>a <sub>p</sub> = 1                    **z = 40 ft<br>R <sub>p</sub> = 2.5                ** Assume worst<br>Ω <sub>0</sub> = 2.0                case location.<br>a <sub>p</sub> , R <sub>p</sub> , Ω <sub>0</sub> per ASCE 7-10 | X 40 ft. RF<br>0 ft. GF<br>or below ground | LOAD COMBINATION<br>LRFD 2013<br>( 0.9 DL + 2.50 E ) |                        |
|   | CUSTOMER:<br>WEIL-McLAIN | DATE:    PRP. BY.:    CAE PIPING JOB #:<br>8/3/2018   |  |  |  |                        |
| EQUIPMENT TAG: BOILER SVF 1100  |                          | APPLIED SEISMIC FORCE/ CALCULATIONS:  |  |  | ANCHORAGE TO CONCRETE                                | SHT. NUMBER:<br>1 OF 1 |
| EQUIPMENT Information:<br>W <sub>p</sub> = max. operating weight = 2695 lbs.  |                          | $F_p / W_p = ( 0.4 \times a_p \times S_{ds} \times ( 1 + ( 2 \times ( z / h ) ) ) / ( R_p / I_p ) ) = 0.96$ $F_p / W_p = 0.96g ; F_{p,min} / W_p = 0.3 \times S_{ds} \times I_p = 0.60 ; F_{p,max} / W_p = 1.6 \times S_{ds} \times I_p = 3.20$ $F_{ph} = \text{Applied Lateral Seismic Force} = 2.5 \times 0.96g \times W_p = 6468 \text{ lbs. } \text{"WORST CASE"}$ $F_{pv} = \text{Vertical component of seismic force} = 1.0 \times 0.2 \times S_{ds} \times W_p = 1078 \text{ lbs. } \text{"WORST CASE"}$ |  |  |  |                        |

### ***5.7 Results Evaluation***

Minimum safety factor of **1.76** is obtained in the analyses of the assembly carried out in sections 5.1 to 5.4. The analyses of the joints, welds and bolts, carried out in sections 5.5 to 5.6 also show that they meet and exceed the requirement of AISC. However, the stresses reported in section 5 are local stresses and the average stress through the thickness of the members are much lower and that can be shown by stress linearization through the thickness. However, since even the maximum local peak stresses don't exceed the allowable values, the stress linearization work is skipped here.

## ***6 Conclusion***

Seismic analysis of the boiler, model SVF 1100, is carried out in this report and based on the safety factors reported in section **5.7**, minimum safety factor of **1.76** is obtained in all the analyses performed in this report.

It is concluded that the design of the structure of the boiler SVF 1100 meets the design requirements of AISC, ASCE7-10 and IBC 2012 standards.





## ***7 References***

[1]- IBC 2012.

[2]- AISC 14<sup>th</sup> Edition.

[3]- ASCE 7-10.

*APPENDIX I- Drawing with COG markup*




*Raymond Maddock*

**Raymond Maddock  
Sr. Product Engineer**

CONFIDENTIAL - The contents of this document are confidential and constitute the exclusive property of Weil-McLain. This document and its contents may not be made public in any manner, distributed or loaned to others, or reproduced or copied either in whole or in part without the prior written consent of Weil-McLain. This drawing has been prepared according to the established standard uniform practices in ASME Y14.5M-1994. Dimensions are in Imperial units (inches) unless otherwise shown. Printed copies of this document are UN-CONTROLLED unless otherwise controlled, stamped and approved. This may not be the current revision.

TITLE  
SVF 1100 - Center Of Gravity Location

TOLERANCES, UNLESS OTHERWISE SPECIFIED  
Angular ±  
1 Place Decimal ±  
2 Place Decimal ±  
3 Place Decimal ±



|            |      |   |       |         |         |
|------------|------|---|-------|---------|---------|
| ECO-3810   | 00   | INITIAL PRODUCTION RELEASE; REVISED TO PRODUCTION REVISION 00 FROM PROTOTYPE REVISION A; ADDED LINE FOR GROUND AND 5.25 AND 39.51 DIMENSIONS. | FH    | DL      | NDB     |
| ECO NUMBER | REV. | DESCRIPTION   | Drawn | Checked | Approve |
| REVISIONS  |      |   |       |         |         |

|  |          |          |     |                   |        |               |  |
|--|----------|----------|-----|-------------------|--------|---------------|--|
| SEE LATEST REVISION E.C.O. FOR APPROVALS |          |          |     | DRAWING           |        | REVISION      |  |
| ECO NO                                   | ECO-3810 | CHECKER  | DL  | No. SVF-E004-BDOC |        | 00            |  |
| DRAWN                                    | FH       | APPROVER | NDB | DO NOT SCALE      | SIZE B | SHEET: 1 OF 1 |  |

*Appendix 2- Anchor Bolt Calculation Report*


[www.hilti.us](http://www.hilti.us)

Company: CAEP  
 Specifier: S.S.  
 Address:  
 Phone | Fax: |  
 E-Mail:

Page: 1  
 Project: SVF 1100  
 Sub-Project | Pos. No.: WM  
 Date: 8/5/2018

**Specifier's comments:**
**1 Input data**


|                                    |  |
|------------------------------------|--|
| <b>Anchor type and diameter:</b>   | <b>Kwik Bolt TZ - CS 3/8 (2 3/4)</b>   |
| Effective embedment depth:         | $h_{ef} = 2.750$ in., $h_{nom} = 3.063$ in.  |
| Material:                          | Carbon Steel   |
| Evaluation Service Report:         | ESR-1917   |
| Issued   Valid:                    | 6/1/2016   5/1/2017  |
| Proof:                             | Design method ACI 318 / AC193  |
| Stand-off installation:            | $e_b = 0.000$ in. (no stand-off); $t = 0.375$ in.  |
| Anchor plate:                      | $l_x \times l_y \times t = 5.000$ in. $\times$ $5.000$ in. $\times$ $0.375$ in.; (Recommended plate thickness: not calculated)         |
| Profile:                           | no profile   |
| Base material:                     | cracked concrete, 3000, $f_c' = 3000$ psi; $h = 5.000$ in.   |
| Reinforcement:                     | tension: condition B, shear: condition B; no supplemental splitting reinforcement present<br>edge reinforcement: none or $<$ No. 4 bar |
| Seismic loads (cat. C, D, E, or F) | no   |

**Geometry [in.] & Loading [lb, in.lb]**


www.hilti.us

 Company: CAEP  
 Specifier: S.S.  
 Address:  
 Phone | Fax: |  
 E-Mail:

 Page: 2  
 Project: SVF 1100  
 Sub-Project | Pos. No.: WM  
 Date: 8/5/2018


## 2 Load case/Resulting anchor forces

Load case: Design loads

### Anchor reactions [lb]

Tension force: (+Tension, -Compression)

| Anchor | Tension force | Shear force | Shear force x | Shear force y |
|--------|---------------|-------------|---------------|---------------|
| 1      | 583           | 86          | 86            | 8             |
| 2      | 19            | 172         | 86            | 149           |
| 3      | 995           | 56          | -55           | 8             |
| 4      | 431           | 159         | -55           | 149           |

 max. concrete compressive strain: 0.20 [‰]  
 max. concrete compressive stress: 883 [psi]  
 resulting tension force in (x/y)=(-0.834/0.610): 2029 [lb]  
 resulting compression force in (x/y)=(2.093/-1.943): 534 [lb]


## 3 Tension load

|                              | Load $N_{ua}$ [lb] | Capacity $\phi N_n$ [lb] | Utilization $\beta_N = N_{ua}/\phi N_n$ | Status |
|------------------------------|--------------------|--------------------------|---|--------|
| Steel Strength*              | 995                | 4875                     | 21                                      | OK     |
| Pullout Strength*            | 995                | 2246                     | 45                                      | OK     |
| Concrete Breakout Strength** | 2029               | 3720                     | 55                                      | OK     |

\* anchor having the highest loading \*\*anchor group (anchors in tension)

### 3.1 Steel Strength

 $N_{sa}$  = ESR value refer to ICC-ES ESR-1917  
 $\phi N_{sa} \geq N_{ua}$  ACI 318-08 Eq. (D-1)

#### Variables

| $A_{se,N}$ [in. <sup>2</sup> ] | $f_{uta}$ [psi] |
|--------------------------------|-----------------|
| 0.05                           | 125000          |

#### Calculations

|               |
|---------------|
| $N_{sa}$ [lb] |
| 6500          |

#### Results

| $N_{sa}$ [lb] | $\phi_{steel}$ | $\phi N_{sa}$ [lb] | $N_{ua}$ [lb] |
|---------------|----------------|--------------------|---------------|
| 6500          | 0.750          | 4875               | 995           |

[www.hilti.us](http://www.hilti.us)

Company: CAEP  
 Specifier: S.S.  
 Address:  
 Phone | Fax: |  
 E-Mail:

Page: 3  
 Project: SVF 1100  
 Sub-Project | Pos. No.: WM  
 Date: 8/5/2018

### 3.2 Pullout Strength

$$N_{pn,f_c} = N_{p,2500} \sqrt{\frac{f'_c}{2500}} \quad \text{refer to ICC-ES ESR-1917}$$

$$\phi N_{pn,f_c} \geq N_{ua} \quad \text{ACI 318-08 Eq. (D-1)}$$

#### Variables

|              |                   |
|--------------|-------------------|
| $f'_c$ [psi] | $N_{p,2500}$ [lb] |
| 3000         | 3155              |

#### Calculations

$$\frac{\sqrt{\frac{f'_c}{2500}}}{1.095}$$

#### Results

|                   |                   |                        |               |
|-------------------|-------------------|------------------------|---------------|
| $N_{pn,f_c}$ [lb] | $\phi_{concrete}$ | $\phi N_{pn,f_c}$ [lb] | $N_{ua}$ [lb] |
| 3456              | 0.650             | 2246                   | 995           |

### 3.3 Concrete Breakout Strength

$$N_{cbg} = \left( \frac{A_{Nc}}{A_{Nc0}} \right) \Psi_{ec,N} \Psi_{ed,N} \Psi_{c,N} \Psi_{cp,N} N_b \quad \text{ACI 318-08 Eq. (D-5)}$$

$$\phi N_{cbg} \geq N_{ua} \quad \text{ACI 318-08 Eq. (D-1)}$$

$$A_{Nc} \quad \text{see ACI 318-08, Part D.5.2.1, Fig. RD.5.2.1(b)}$$

$$A_{Nc0} = 9 h_{ef}^2 \quad \text{ACI 318-08 Eq. (D-6)}$$

$$\Psi_{ec,N} = \left( \frac{1}{1 + \frac{2 e_{c,N}}{3 h_{ef}}} \right) \leq 1.0 \quad \text{ACI 318-08 Eq. (D-9)}$$

$$\Psi_{ed,N} = 0.7 + 0.3 \left( \frac{c_{a,min}}{1.5 h_{ef}} \right) \leq 1.0 \quad \text{ACI 318-08 Eq. (D-11)}$$

$$\Psi_{cp,N} = \text{MAX} \left( \frac{c_{a,min}}{c_{ac}}, \frac{1.5 h_{ef}}{c_{ac}} \right) \leq 1.0 \quad \text{ACI 318-08 Eq. (D-13)}$$

$$N_b = k_c \lambda \sqrt{f'_c} h_{ef}^{1.5} \quad \text{ACI 318-08 Eq. (D-7)}$$

#### Variables

|                |                  |                  |                   |              |
|----------------|------------------|------------------|-------------------|--------------|
| $h_{ef}$ [in.] | $e_{c1,N}$ [in.] | $e_{c2,N}$ [in.] | $c_{a,min}$ [in.] | $\Psi_{c,N}$ |
| 2.750          | 0.834            | 0.610            | 6.000             | 1.000        |

|                |       |           |              |
|----------------|-------|-----------|--------------|
| $c_{ac}$ [in.] | $k_c$ | $\lambda$ | $f'_c$ [psi] |
| 4.125          | 17    | 1         | 3000         |

#### Calculations

|                              |                               |                |                |               |               |            |
|------------------------------|-------------------------------|----------------|----------------|---------------|---------------|------------|
| $A_{Nc}$ [in. <sup>2</sup> ] | $A_{Nc0}$ [in. <sup>2</sup> ] | $\Psi_{ec1,N}$ | $\Psi_{ec2,N}$ | $\Psi_{ed,N}$ | $\Psi_{cp,N}$ | $N_b$ [lb] |
| 126.56                       | 68.06                         | 0.832          | 0.871          | 1.000         | 1.000         | 4246       |

#### Results

|                |                   |                     |               |
|----------------|-------------------|---------------------|---------------|
| $N_{cbg}$ [lb] | $\phi_{concrete}$ | $\phi N_{cbg}$ [lb] | $N_{ua}$ [lb] |
| 5723           | 0.650             | 3720                | 2029          |

www.hilti.us

 Company: CAEP  
 Specifier: S.S.  
 Address:  
 Phone | Fax: |  
 E-Mail:

 Page: 4  
 Project: SVF 1100  
 Sub-Project | Pos. No.: WM  
 Date: 8/5/2018

## 4 Shear load

|   | Load $V_{ua}$ [lb] | Capacity $\phi V_n$ [lb] | Utilization $\beta_V = V_{ua}/\phi V_n$ | Status |
|---|--------------------|--------------------------|---|--------|
| Steel Strength*                         | 172                | 2337                     | 8                                       | OK     |
| Steel failure (with lever arm)*         | N/A                | N/A                      | N/A                                     | N/A    |
| Pryout Strength*                        | 172                | 2764                     | 7                                       | OK     |
| Concrete edge failure in direction y+** | 359                | 1868                     | 20                                      | OK     |

\* anchor having the highest loading \*\*anchor group (relevant anchors)

### 4.1 Steel Strength

 $V_{sa}$  = ESR value refer to ICC-ES ESR-1917  
 $\phi V_{steel} \geq V_{ua}$  ACI 318-08 Eq. (D-2)

#### Variables

|                                |                 |
|--------------------------------|-----------------|
| $A_{se,V}$ [in. <sup>2</sup> ] | $f_{uta}$ [psi] |
| 0.05                           | 125000          |

#### Calculations

|               |
|---------------|
| $V_{sa}$ [lb] |
| 3595          |

#### Results

|               |                |                    |               |
|---------------|----------------|--------------------|---------------|
| $V_{sa}$ [lb] | $\phi_{steel}$ | $\phi V_{sa}$ [lb] | $V_{ua}$ [lb] |
| 3595          | 0.650          | 2337               | 172           |

### 4.2 Pryout Strength

$$V_{cp} = k_{cp} \left[ \left( \frac{A_{Nc}}{A_{Nc0}} \right) \psi_{ed,N} \psi_{c,N} \psi_{cp,N} N_b \right] \quad \text{ACI 318-08 Eq. (D-30)}$$

$$\phi V_{cp} \geq V_{ua} \quad \text{ACI 318-08 Eq. (D-2)}$$

 $A_{Nc}$  see ACI 318-08, Part D.5.2.1, Fig. RD.5.2.1(b)

$$A_{Nc0} = 9 h_{ef}^2 \quad \text{ACI 318-08 Eq. (D-6)}$$

$$\psi_{ec,N} = \left( \frac{1}{1 + \frac{2 e_N}{3 h_{ef}}} \right) \leq 1.0 \quad \text{ACI 318-08 Eq. (D-9)}$$

$$\psi_{ed,N} = 0.7 + 0.3 \left( \frac{c_{a,min}}{1.5 h_{ef}} \right) \leq 1.0 \quad \text{ACI 318-08 Eq. (D-11)}$$

$$\psi_{cp,N} = \text{MAX} \left( \frac{c_{a,min}}{c_{ac}}, \frac{1.5 h_{ef}}{c_{ac}} \right) \leq 1.0 \quad \text{ACI 318-08 Eq. (D-13)}$$

$$N_b = k_c \lambda \sqrt{f'_c} h_{ef}^{1.5} \quad \text{ACI 318-08 Eq. (D-7)}$$

#### Variables

|          |                |                  |                  |                   |
|----------|----------------|------------------|------------------|-------------------|
| $k_{cp}$ | $h_{ef}$ [in.] | $e_{c1,N}$ [in.] | $e_{c2,N}$ [in.] | $c_{a,min}$ [in.] |
| 2        | 2.750          | 0.000            | 0.000            | 6.000             |

|              |                |       |           |              |
|--------------|----------------|-------|-----------|--------------|
| $\psi_{c,N}$ | $c_{ac}$ [in.] | $k_c$ | $\lambda$ | $f'_c$ [psi] |
| 1.000        | 4.125          | 17    | 1         | 3000         |

#### Calculations

|                              |                               |                |                |               |               |            |
|------------------------------|-------------------------------|----------------|----------------|---------------|---------------|------------|
| $A_{Nc}$ [in. <sup>2</sup> ] | $A_{Nc0}$ [in. <sup>2</sup> ] | $\psi_{ec1,N}$ | $\psi_{ec2,N}$ | $\psi_{ed,N}$ | $\psi_{cp,N}$ | $N_b$ [lb] |
| 31.64                        | 68.06                         | 1.000          | 1.000          | 1.000         | 1.000         | 4246       |

#### Results

|               |                   |                    |               |
|---------------|-------------------|--------------------|---------------|
| $V_{cp}$ [lb] | $\phi_{concrete}$ | $\phi V_{cp}$ [lb] | $V_{ua}$ [lb] |
| 3948          | 0.700             | 2764               | 172           |



[www.hilti.us](http://www.hilti.us)

Company: CAEP  
 Specifier: S.S.  
 Address:  
 Phone | Fax: |  
 E-Mail:

Page: 5  
 Project: SVF 1100  
 Sub-Project | Pos. No.: WM  
 Date: 8/5/2018

### 4.3 Concrete edge failure in direction y+

$$V_{cbg} = \left( \frac{A_{Vc}}{A_{Vc0}} \right) \Psi_{ec,V} \Psi_{ed,V} \Psi_{c,V} \Psi_{h,V} \Psi_{parallel,V} V_b \quad \text{ACI 318-08 Eq. (D-22)}$$

$$\phi V_{cbg} \geq V_{ua} \quad \text{ACI 318-08 Eq. (D-2)}$$

$A_{Vc}$  see ACI 318-08, Part D.6.2.1, Fig. RD.6.2.1(b)

$$A_{Vc0} = 4.5 c_{a1}^2 \quad \text{ACI 318-08 Eq. (D-23)}$$

$$\Psi_{ec,V} = \left( \frac{1}{1 + \frac{2e_v}{3c_{a1}}} \right) \leq 1.0 \quad \text{ACI 318-08 Eq. (D-26)}$$

$$\Psi_{ed,V} = 0.7 + 0.3 \left( \frac{c_{a2}}{1.5c_{a1}} \right) \leq 1.0 \quad \text{ACI 318-08 Eq. (D-28)}$$

$$\Psi_{h,V} = \sqrt{\frac{1.5c_{a1}}{h_a}} \geq 1.0 \quad \text{ACI 318-08 Eq. (D-29)}$$

$$V_b = \left( 7 \left( \frac{l_e}{d_a} \right)^{0.2} \sqrt{d_a} \right) \lambda \sqrt{f'_c} c_{a1}^{1.5} \quad \text{ACI 318-08 Eq. (D-24)}$$

#### Variables

| $c_{a1}$ [in.] | $c_{a2}$ [in.] | $e_{cV}$ [in.] | $\Psi_{c,V}$ | $h_a$ [in.]         |
|----------------|----------------|----------------|--------------|---------------------|
| 4.000          | 6.000          | 1.178          | 1.000        | 5.000               |
| $l_e$ [in.]    | $\lambda$      | $d_a$ [in.]    | $f'_c$ [psi] | $\Psi_{parallel,V}$ |
| 2.750          | 1.000          | 0.375          | 3000         | 1.000               |

#### Calculations

| $A_{Vc}$ [in. <sup>2</sup> ] | $A_{Vc0}$ [in. <sup>2</sup> ] | $\Psi_{ec,V}$ | $\Psi_{ed,V}$ | $\Psi_{h,V}$ | $V_b$ [lb] |
|------------------------------|-------------------------------|---------------|---------------|--------------|------------|
| 75.00                        | 72.00                         | 0.836         | 1.000         | 1.095        | 2798       |

#### Results

| $V_{cbg}$ [lb] | $\phi_{concrete}$ | $\phi V_{cbg}$ [lb] | $V_{ua}$ [lb] |
|----------------|-------------------|---------------------|---------------|
| 2669           | 0.700             | 1868                | 359           |

### 5 Combined tension and shear loads

| $\beta_N$ | $\beta_V$ | $\zeta$ | Utilization $\beta_{N,V}$ [%] | Status |
|-----------|-----------|---------|-------------------------------|--------|
| 0.546     | 0.192     | 5/3     | 43                            | OK     |

$$\beta_{NV} = \beta_N^\zeta + \beta_V^\zeta \leq 1$$

### 6 Warnings

- Load re-distributions on the anchors due to elastic deformations of the anchor plate are not considered. The anchor plate is assumed to be sufficiently stiff, in order not to be deformed when subjected to the loading! Input data and results must be checked for agreement with the existing conditions and for plausibility!
- Condition A applies when supplementary reinforcement is used. The  $\Phi$  factor is increased for non-steel Design Strengths except Pullout Strength and Pryout strength. Condition B applies when supplementary reinforcement is not used and for Pullout Strength and Pryout Strength. Refer to your local standard.
- Refer to the manufacturer's product literature for cleaning and installation instructions.
- Checking the transfer of loads into the base material and the shear resistance are required in accordance with ACI 318 or the relevant standard!

**Fastening meets the design criteria!**

[www.hilti.us](http://www.hilti.us)

Company: CAEP  
 Specifier: S.S.  
 Address:  
 Phone | Fax: |  
 E-Mail:

Page: 6  
 Project: SVF 1100  
 Sub-Project | Pos. No.: WM  
 Date: 8/5/2018


## 7 Installation data

Anchor plate, steel: -  
 Profile: no profile  
 Hole diameter in the fixture:  $d_f = 0.438$  in.  
 Plate thickness (input): 0.375 in.  
 Recommended plate thickness: not calculated  
 Drilling method: Hammer drilled  
 Cleaning: Manual cleaning of the drilled hole according to instructions for use is required.

Anchor type and diameter: Kwik Bolt TZ - CS 3/8 (2 3/4)  
 Installation torque: 300.000 in.lb  
 Hole diameter in the base material: 0.375 in.  
 Hole depth in the base material: 3.375 in.  
 Minimum thickness of the base material: 5.000 in.

### 7.1 Recommended accessories

| Drilling   | Cleaning   | Setting   |
|--|--|---|
| <ul style="list-style-type: none"> <li>Suitable Rotary Hammer</li> <li>Properly sized drill bit</li> </ul> | <ul style="list-style-type: none"> <li>Manual blow-out pump</li> </ul> | <ul style="list-style-type: none"> <li>Torque wrench</li> <li>Hammer</li> </ul> |



### Coordinates Anchor in.

| Anchor | x      | y      | C-x   | C+ <sub>x</sub> | C-y   | C+ <sub>y</sub> |
|--------|--------|--------|-------|-----------------|-------|-----------------|
| 1      | -1.500 | -1.500 | 6.000 | 9.000           | 6.000 | 9.000           |
| 2      | 1.500  | -1.500 | 9.000 | 6.000           | 6.000 | 9.000           |
| 3      | -1.500 | 1.500  | 6.000 | 9.000           | 9.000 | 6.000           |
| 4      | 1.500  | 1.500  | 9.000 | 6.000           | 9.000 | 6.000           |



www.hilti.us

Company: CAEP  
Specifier: S.S.  
Address:  
Phone | Fax: |  
E-Mail:

Page: 7  
Project: SVF 1100  
Sub-Project | Pos. No.: WM  
Date: 8/5/2018

## 8 Remarks; Your Cooperation Duties

- Any and all information and data contained in the Software concern solely the use of Hilti products and are based on the principles, formulas and security regulations in accordance with Hilti's technical directions and operating, mounting and assembly instructions, etc., that must be strictly complied with by the user. All figures contained therein are average figures, and therefore use-specific tests are to be conducted prior to using the relevant Hilti product. The results of the calculations carried out by means of the Software are based essentially on the data you put in. Therefore, you bear the sole responsibility for the absence of errors, the completeness and the relevance of the data to be put in by you. Moreover, you bear sole responsibility for having the results of the calculation checked and cleared by an expert, particularly with regard to compliance with applicable norms and permits, prior to using them for your specific facility. The Software serves only as an aid to interpret norms and permits without any guarantee as to the absence of errors, the correctness and the relevance of the results or suitability for a specific application.
- You must take all necessary and reasonable steps to prevent or limit damage caused by the Software. In particular, you must arrange for the regular backup of programs and data and, if applicable, carry out the updates of the Software offered by Hilti on a regular basis. If you do not use the AutoUpdate function of the Software, you must ensure that you are using the current and thus up-to-date version of the Software in each case by carrying out manual updates via the Hilti Website. Hilti will not be liable for consequences, such as the recovery of lost or damaged data or programs, arising from a culpable breach of duty by you.